

Status	Severity	Event Name	Event Type	Notes	% Of Plants	Material Costs	Plant Names	Tags
In Progress	critical	Morris Hills HS Meter 2 mismatch by 20%	Plant - Meter	meter- \$1607 plus installation - 4 manhours -	20	\$ 2,207.00	Morris I - Morris Hills Regional District - Morris Hills High School	NJ, \$\$\$\$, UnApp
In Progress	critical	Mountain Lakes HS Inv 6-1 Off - Major Repair	Plant - Communication	\$12987.50 repair estimate from Jean	60	\$ 12,987.50	Morris I - Mountain Lakes School District - Mountain Lakes High School	NJ, \$\$\$\$, UnApp, FFL
New	critical	Troy Hills SD - Central MS inv 2 Off	Plant - Inverter	New event - developing estimate	50	TBD	Morris I - Parsippany-Troy Hills School District - Central Middle School	NJ, \$\$\$\$, UnApp
New	critical	Troy Hills ES - Meter is reading negative first half of day	Plant - Meter	New event - developing estimate	30	TBD	Morris I - Parsippany-Troy Hills School District - Troy Hills School	NJ, \$\$\$\$, UnApp
New	major	West Morris Mendham Inverter filters need replacement	Plant - Inverter - Filter			\$ 1,343.44	Morris I - West Morris Regional High School District - West Morris Mendham High S	NJ, \$\$\$\$, UnApp, Approved
New	major	Morris 1 Knolls HS Inverter filters need to be replaced	Plant - Inverter - Filter			\$ 175.00	Morris I - Morris Hills Regional District - Morris Knolls High School	NJ, \$\$\$\$, UnApp, Approved
New	major	Voter Machine 3 Strings Isolated	Plant - Panel Replacement	3 panels - \$450 plus 6 hrs labor - \$1350.00	8	\$ 1,350.00	Morris I - County of Morris - Voter Machine Tech Center	NJ, \$\$\$\$, UnApp
New	major	Mountain Lakes 2 Isolated Strings	Plant - Panel Replacement	\$150 plus 3 hrs labor - \$600	4	\$ 600.00	Morris I - Mountain Lakes School District - Mountain Lakes High School	NJ, \$\$\$\$, UnApp
New	minor	West Morris Mendham 1 String Isolated	Plant - Panel Replacement	Replace 2 panels - \$300 plus 3 hrs labor - \$750 - CB 2	5	\$ 750.00	Morris I - West Morris Regional High School District - West Morris Mendham High S	NJ, \$\$\$\$, UnApp
Critical and Major repairs are highly recommended (please note: the cost for 1 inverter and 1 meter repair is still in progress)				Recommended Critical / Major Repairs Subtotal:		\$ 19,412.94		
New	minor	Parsippany HS Signage Fading	Site - Health & Safety			\$ 50.00	Morris I - Parsippany-Troy Hills School District - Parsippany High School	NJ, \$\$\$\$, UnApp, Approved
New	minor	Morris Hills HS Signage Fading	Site - Health & Safety			\$ 100.00	Morris I - Morris Hills Regional District - Morris Hills High School	NJ, \$\$\$\$, UnApp, Approved
New	minor	Central MS Signage Fading	Site - Health & Safety			\$ 150.00	Morris I - Parsippany-Troy Hills School District - Central Middle School	NJ, \$\$\$\$, UnApp, Approved
New	minor	Troy Hills School Signage Fading	Site - Health & Safety			\$ 100.00	Morris I - Parsippany-Troy Hills School District - Troy Hills School	NJ, \$\$\$\$, UnApp, Approved
New	minor	Morris Hills HS Wire Management	Plant - Wire Management	4 hrs for wire management - \$600		\$ 600.00	Morris I - Morris Hills Regional District - Morris Hills High School	NJ, \$\$\$\$, UnApp
New	minor	Schuyler Minor wire management	Plant - Wire Management			\$ 420.00	Morris I - County of Morris - Schuyler Parking Facility	NJ, \$\$\$\$, UnApp, Approved
Minor repair items above are highly recommended:				Recommended Minor Repairs Subtotal:		\$ 1,420.00		
In Progress	major	West Morris Mendham Ballast block deteriorating in spots	Plant - Ballast Block Replacement			TBD	Morris I - West Morris Regional High School District - West Morris Mendham High S	NJ, \$\$\$\$, UnApp
In Progress	major	Morris Hills HS Ballast block starting to deteriorate	Plant - Ballast Block Replacement			TBD	Morris I - Morris Hills Regional District - Morris Hills High School	NJ, \$\$\$\$, UnApp
In Progress	major	Morris 1 Knolls HS Ballast block starting to deteriorate	Plant - Ballast Block Replacement			TBD	Morris I - Morris Hills Regional District - Morris Knolls High School	NJ, \$\$\$\$, UnApp
Major repair items above are highly recommended (please note: subcontractor pricing needed to complete estimate process):				Recommended Major Repairs Subtotal:		TBD		
New	minor	Voter Tech CB1 has rust on the backing plate	Plant - Post-PM Repair Items to Resolve			\$ 105.00	Morris I - County of Morris - Voter Machine Tech Center	NJ, \$\$\$\$, UnApp, Approved
New	minor	Morris Hills HS Surface rust on inverters	Plant - Post-PM Repair Items to Resolve			\$ 1,470.00	Morris I - Morris Hills Regional District - Morris Hills High School	NJ, \$\$\$\$, UnApp, Approved
New	minor	Parsippany HS Surface rust on CBs	Plant - Post-PM Repair Items to Resolve			\$ 210.00	Morris I - Parsippany-Troy Hills School District - Parsippany High School	NJ, \$\$\$\$, UnApp, Approved
New	minor	Morris 1 Knolls HS Inverter has patch of rust	Plant - Post-PM Repair Items to Resolve			\$ 735.00	Morris I - Morris Hills Regional District - Morris Knolls High School	NJ, \$\$\$\$, UnApp, Approved
New	minor	Schuyler Inverter has patches of rust	Plant - Post-PM Repair Items to Resolve			\$ 735.00	Morris I - County of Morris - Schuyler Parking Facility	NJ, \$\$\$\$, UnApp, Approved
New	minor	Schuyler CBs have surface Rust	Plant - Post-PM Repair Items to Resolve			\$ 210.00	Morris I - County of Morris - Schuyler Parking Facility	NJ, \$\$\$\$, UnApp, Approved
New	minor	Voter Machine- Inverter Painting	Plant - Post-PM Repair Items to Resolve	Inverter onsite needs painting			Morris I - County of Morris - Voter Machine Tech Center	NJ, \$\$\$\$, UnApp
New	minor	Schuyler Parking Deck- CB New labels	Plant - Post-PM Repair Items to Resolve	Labeler can be used to relabel Combiner boxes			Morris I - County of Morris - Schuyler Parking Facility	NJ, \$\$\$\$, UnApp
				Optional Minor Repairs:		\$ 3,465.00		